This series of control sequences provides single duct bypass variable air volume cooling with up to three stages of electric or hot water reheat and morning warm up/changeover. As space temperature drops, airflow to the zone is reset from full open to the minimum airflow setpoint. As space temperature continues to drop, reheat is energized in stages to satisfy the load. Warm air is sensed by an electronic duct sensor, causing the sequence to reverse for morning warm up (reheat is disabled). The minimum airflow setpoint is field calibrated by adjusting the damper linkage. The maximum airflow setpoint is obtained through adjustment of an upstream damper provided by others.

